

2021 Annual Drinking Water Quality Report
City of Balch Springs
PWS ID Number: TX0570032
Consumer Confidence Report (CCR)

The source of drinking water used by the City of Balch Springs residents, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. Annual Water Quality Report for the period of January 1 to December 31, 2021. This report is intended to provide you with important information about your drinking water and efforts made by the water system to provide safe drinking water. For more information regarding this report contact:

Name: William Freeman
Phone: 972-286-4477 x207

Our Drinking Water Is Regulated

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached papers. The City of Balch Springs is a "Superior" Rated Water System, the highest rating of the Texas Commission on Environmental Quality. Balch Springs water meets or exceeds all State and Federal requirements for water quality and is safe to drink. We hope this information helps you become more knowledgeable about what's in your drinking water.

Public Participation Opportunities

Date: 2nd and 4th Monday of the month. **Time:** 7:00 p.m. **Location:** 13503 Alexander Road, Balch Springs, TX. **Phone Number:** 972-286-4477 x 210. To learn about future public meetings (concerning your drinking water) or to request to schedule one, please call us.

En Español

Este informe incluye informacion importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en español, favor de llamar al tel 972-286-4477 x 221.

Information on Sources of Water

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and the sources of drinking water (both tap water and bottled water) including rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material and can pick up substances resulting from the presence of contaminants that may be present in source water. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and Inorganic contaminants, such as salts and metals which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems. - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Where do we get our drinking water?

The source of drinking water used by the City of Balch Springs is Purchased Pretreated Surface Water. The City of Balch Springs purchases 100% of its drinking water from the City of Dallas (PWS #0570004). Balch Springs uses surface water (thru DWU) from seven sources: Elm Fork of the Trinity River, Lake Ray Roberts, Lake Lewisville, Lake Grapevine, Lake Ray Hubbard, Lake Tawakoni, and Lake Fork.

Water Loss

In the water loss audit submitted to the Texas Water Development Board for the time period of January 1, 2021 to December 31, 2021, The City of Balch Springs' system lost an estimated 7% of the system input volume. If you have any questions about the water loss audit, please call William Freeman at 972-286-4477 X207.

Special Notice

Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791). If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Secondary Contaminants

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents

are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

Information about Water Source Assessments

The TCEQ has completed a source water assessment for all drinking water systems that own their own sources. The report describes the susceptibility and types of constituents that may come into contact with your drinking water based on human activities and natural conditions. The system(s) from which we purchase our water received the assessment report. For more information on the source water assessments and protection at our system contact William Freeman @ 972-286-4477 X207.

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Level 1 Assessment: A Level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an Ecoli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

LAAR: Locational Running Annual Average is the average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Maximum Contaminant Level Goal: or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum residual disinfectant level goal or MRDGL: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDGLs do not reflect the benefits of the use of disinfectants to control microbial contaminant.

Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Avg.: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Ppm: milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.

Ppb: micrograms per liter or parts per billion – one ounce in 7,350,000 gallons of water.

Na: Not applicable

Water Quality Test Results

Contaminants – All testing for the following contaminants performed by Dallas Water Utilities. All Data provided from that testing was provided to the City of Balch Spring by Dallas Water Utilities:

Inorganic Contaminants	Year of Range	LEVEL Average	LEVEL Minimum	LEVEL Maximum	MCL	MCLG	Unit of Measure	Source Contaminates
Flouride	2021	0.674	0.648	0.715	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth
Nitrate (as N)	2021	0.526	0.396	0.666	10	10	ppm	Run off from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Nitrite (as N)	2013	0.017	<.004	0.0315	1	1	ppm	Run off from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Cyanide	2021	71.8	38.3	113	200	200	ppm	Run off from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Bromate	2019	5	<1	13	10(A)	0	ppb	By-Product of drinking water disinfection
Antimony	2016	0.09	<.200	0.27	6	6	ppb	Discharge from refineries, fire retardants, ceramics, electronics, solder
Arsenic	2019	0	0	0	10	0	ppb	Erosion of natural deposits; runoff from orchards; runoff from glass & electronic production wastes
Barium	2021	0.029	0.024	0.033	2	2	ppm	Discharge from drilling waste; discharge from metal refineries; erosion of natural deposits
Chromium (total)	2020	1.03	<1	1.8	100	100	ppb	Discharge from steel or pulp mills; erosion of natural deposits
Manganese	2013	2.16	<0.400	6.49	50	-	ppb	Naturally occurs in rocks and soil
Radioactive								
Combined Radium (226 & 228)	2011	1	1	1	5	0	pCi/L****	Erosion of natural deposits
Gross beta partical activity	2017	5.1	4.2	6.6	50	0	pCi/L****	Decay of natural or man-made deposits

Organic Contaminants

Atrazine	2021	0.13	0.1	0.2	3	3	ppb	Run off from herbicide used on row crops
----------	------	------	-----	-----	---	---	-----	--

Total Organic Carbon	Year of Range	LEVEL Average	LEVEL Minimum	LEVEL Maximum	TT (no MCL)****	Unit of Measure	Source Contaminates
Total Organic Carbon	2021	2.89	2.18	3.01	35% removal/SUVA	ppm	Naturally present in enviroment

Turbidity	Year of Range	Highest Single Measurments	Lowest Monthly %		Trubidit y Limits	Unit of Measure	Source Contaminates
			of Samples Meeting Limits				
Turbidity	2021	0.45	100%		1.0 (TT)	NTU	Soil Runoff
Lowest Monthly % meeting limit	2021	99%	95% of Readings <3%			NTU	Soil Runoff

Haloacetic Acids (HAA5) *	2021	6	4-7.8	No goal for the total	60	ppb	n	By-product of drinking water chlorination
------------------------------	------	---	-------	-----------------------	----	-----	---	---

Total Trihalomethanes (TThm) *	2021	13	8.48-15.3	No goal for the total	80	ppb	n	By-product of drinking water chlorination
--------------------------------	------	----	-----------	-----------------------	----	-----	---	---

Disinfection

	Year	Average Residual	Lowest Residual Taken	Highest Residual Taken	MRDL	MRDLG	Unit of Measurement	
Total Chlorine Residual	2021	2.47	1.00	3.75	4*	4*	ppm	In distribution system - Water additive used to control microbes

	Sample Year	Amount Detected	MCL	MCLG	Unit of Measurement	Source of contaminant
Nitrate	2021	.451 mg/L	10	10	ppm	Run-off from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits.

Total Coliforms

	Sample Year	Highest Monthly % of Positive Samples	MCL	Unit of Measure	Source of contaminant
Total Coliform (Dallas)	2021	0.30%	5% or more of monthly samples	Found / Not Found	Naturally present in the environment
Total Coliform (Balch Springs)	2021	0.06%	5% or more of monthly samples	Found / Not Found	Naturally present in the environment

NOTICE: During the past year we were required to conduct one Level 1 assessment. One Level 1 assessment was completed. We were not required to take corrective actions. If you have any questions regarding this Level 1 assessment contact William Freeman at 972-286-4477 x207.

Violations

Violation Type	Violation Begin	Violation End	Violation Explanation
No Violations for 2021	N/A	N/A	N/A

Note on Violations:

TCEQ recently completed a review of Public Notice Violations that were historically present in our database. This review was done at the request of the Environmental Protection Agency and was triggered by the TCEQ migration to the Safe Drinking Water Information System (SDWIS). Following EPA guidelines, TCEQ returned to compliance many PN violations that had existed but may not have been reported on a prior year CCR. We strongly encourage you to check Drinking Water Watch (HYPERLINK <http://dww.tceq.texas.gov/DWW/>) for current status of any violations display on this page.